

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. LAB/UPJN/09

Dated: 07/03/2026

It is certified that an inspection team headed by Dr. Shamshad Ahmad (Technical Manager) from District Water Testing Laboratory Uttar Pradesh Jal Nigam Bahraich Inspected the Brain Discovery Global School Nanpara Bahraich 271865 on 07.03.2026 and on the basis of Water Test Report (Attached) bearing no. DWTL202632 Dated. 06.03.2026 of District Water Testing Laboratory Uttar Pradesh Jal Nigam Bahraich Certified that Brain Discovery Global School Nanpara Bahraich 271865 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till 06.03.2027

Signature with Seal:.....


Technical Manager
District Water Analysis Laboratory
Bahraich, U.P.

Name.....

Dr. Shamshad Ahmad

Designation.....


Technical Manager

Name & Address of the Office / Department:.....


District
Water Testing Laboratory Jal Nigam
Bahraich

To,

Brain Discovery Global School
Nanpara Bahraich
271865


Manager

Brain Discovery Global School
Banjaran Tanda, Nanpara-Bahraich


Principal
Brain Discovery Global School
Banjaran Tanda, Nanpara-Bahraich

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Drinking Water Sanitary Inspection form for Piped Water Supply

I. Type of facility: Piped water supply

1. General Information:

- a) District: Brain Discovery Global School Bahraich
 b) Location: Brain Discovery Global School Nonpara Bahraich
 c) Date of Visit: 7/3/26

4. Water samples taken? Yes Sample Nos. 1 E.coli/ 100 ml. 0

II. Specific diagnosis information for assessment:

(Please indicate at which sample sites the risk was identified)

Survey Checklist			
S.N	Survey Points	No Risk (Yes)	Risk (No)
1	Do any stand posts leak?	Yes	
2	Does surface water collect around any Tap Water?	Yes	
3	Is the area uphill of any Tap Water eroded?	Yes	
4	Are pipes exposed close to any Tap Water?	Yes	
5	Is Human excreta on the ground within 10m of any Tap Water?	Yes	
6	Is there a sewer within 30m of any Tap Water?	Yes	
7	Has there been a disconnuity in the last 10 days at any stand post?	Yes	
8	Are there signs of leaks in the main pipes?	Yes	
9	Do the community report any pipe breaks in the last week?	Yes	
10	Is the main pipe exposed anywhere in the vicinity?	Yes	
Total Score of Risk			

Risk Score Card			
Risk Hazard	Risk Score	Risk Category Identified	Remark
Low	0-3	0	Low Risk
Medium	3-5		
High	6-8		
Very High	9-10		

III. Results and recommendation: As per visit found there is no or Low Risk Hazards in the vicinity of school.

The following important points of risk were noted: (list nos. 1-10)

As per visit 8 water sample tested Report there is no or Low Risk hazards 8 water (drinking water) source are safe.

Signature of surveyor: Neha Singh
 Manager

Suman Singh
 Principal

Comments:

Brain Discovery Global School
Nonpara-Bahraich
Brain Discovery Global School
Baniaran Tanda, Nonpara-Bahraich
Technical Manager
Water Analysis Lab



Analysis Report



District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), BAHRAICH
Plot No. 2763, Jal Nigam Colony, Jail Road Bahraich, Uttar Pradesh-271801

Rept No. 32	Chemical Test: DWTL202632	Date of Rep	07.03.2026	S.No.	32	Page No.	1/1
ULR No.	TC132242600000294F						
Customer Details: BRAIN DISCOVERY GLOBAL SCHOOL							
Office Name and Address of the Customer: Brain Discovery Global School Narendra Campus Imamganj Road Banjaran Tada Nanpara							
Ref Letter No & Date							
Basic details of sample							
District	Bahraich	Block					
Gram Panchayat		Village					
Habitation		Location	Narendra Campus Imamganj Road Banjaran Ta				
Water Source	Tap Water	Sample No.	1				
Quantity of Sample	1000 ml	Date of Collection	06.03.2026				
Receiving Date	06.03.2026	Sample Collector	Dinesh Kumar Tiwari				
Sample Depositer Name	Dinesh Kumar Tiwari						
Analysis Start Date	06.03.2026	Analysis Completion Date	07.03.2026				

Environmental Condition

Temperature

25±2°C

Relative Humidity

Upto 70%

Technical Data of Analysis

S.No.	Parameters	Units	Observed Value	Specified Values as		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH	-	6.93	6.5-8.5	6.5-8.5	APHA 23 Edition 4500-H-B-2023 (Electrometric Method)
2	Turbidity	(NTU)	1.14	1	5	IS 3025 (Part 10):2023 (Nephelometric Method)
3	TDS	(mg/L)	88	500	2000	IS 3025 (Part 16):1984:2021 (Gravimetric Method)
4	Chloride	(mg/L)	6.33	250	1000	IS 3025 (Part 32):2019 (Argentometric Method)
5	Total Alkalinity	(mg/L)	58.66	200	600	IS 3025 (Part 23):2023 (Indicator Method)
6	Total Hardness	(mg/L)	30.66	200	600	IS 3025 (Part 21):2019(EDTA Method)
7	Sulphate	(mg/L)	1.84	200	400	IS 3025(Part 24):2022 (Turbiditic Method)
8	Nitrate	(mg/L)	0	45	45	APHA 23 Edition 4500-NO ₃ -B-2017 (UV-Screening Method)
9	Fluoride	(mg/L)	0	1	1.5	IS 3025(Part 60):2022 (Ion-Selective Electrode)
10	Iron	(mg/L)	0.15	1	1	IS 3025(Part 53):2019 (Phenanthroanthraline Method)
11	Arsenic	(mg/L)	0	0.01	0.01	IS 3025(Part 37):2022 (Spectrophotometric Method)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing based on the sample sent to the laboratory.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. BDL: Below Detection Limit.
6. N.A: Not Applicable.

End of Report

Prepared By

(Shailendra Kumar)

Lab Technician

Neha Singh
Manager

Brain Discovery Global School
Banjaran Tada, Nanpara-Bahraich

Technical Manager
District Level Water Analysis Laboratory
U.P. Jal Nigam
Authorized Signatory

Swaminathan
Principal
Brain Discovery Global School
Banjaran Tada, Nanpara-Bahraich

Technical Manager

Laboratory Contact details-Email-eebahraichlab@gmail.com, Mob-8382064686



Scanned with OKEN Scanner

Analysis Report

District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), BAHRAICH

Plot No. 2763, Jal Nigam Colony, Jail Road Bahraich, Uttar Pradesh-271801

Sl. No. 15 Chemical Test: DWLT202632 Date of Repo 07.03.2026 S.No. 15 Page No. 1/1

Customer Details: BRAIN DISCOVERY GLOBAL SCHOOL

Office Name and Address of the Customer: Brain Discovery Global School Narendra Campus Imanganj Road Banjaran Tada Nanpara

Ref Letter No & Date

Basic details of sample

District	Bahraich	Block	
Gram Panchayat		Village	
Habitation		Location	Narendra Campus Imanganj Road Banjaran T
Water Source	Tap Water	Sample No.	1
Quantity of Sample	1000 ml	Date of Co	06.03.2026
Receiving Date	06.03.2026	Sample Col	Dinesh Kumar Tiwari
Sample Depositer	Dinesh Kumar Tiwari		
Analysis Start Date	07.03.2026	Analysis Completion Date	07.03.2026

Environmental Condition

Temperature	25±2°C	Relative Humidity	Upto 70%
-------------	--------	-------------------	----------

Technical Data of Analysis

S.No.		Units	Observed Value	Specified Values as per		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Total coliform	No. Per 100 ml	0	Nil	Nil	Membrane filtration Technique
2	E. coli	No. Per 100 ml	0	Nil	Nil	Membrane filtration Technique

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepared By

(Shailendra Kumar)
Lab Technician

Manager
Brain Discovery Global School
Banjaran Tada, Nanpara-Bahraich

Technical Manager
Authorized Signatory
District Level Water Analysis Laboratory
Bahraich, U.P, IN

(Shamshad Ahmad)
Principal
Brain Discovery Global School
Banjaran Tada, Nanpara-Bahraich

Laboratory Contact details-Email-eebahraichlab@gmail.com, Mob-8382064686

